



## Product Compliance Laboratory Confirmation of Product Compliance



7/11/2018

**Steelcase IRYS Pod** products have been designed, engineered, and manufactured, to meet or exceed all applicable **ANSI/BIFMA (American National Standards for Office Furnishings)** requirements for safety and performance.

**ANSI/BIFMA X5.6-2016** – Panel Systems Tests

In addition to ANSI/BIFMA Standards the **IRYS Pod** product has been tested and found to be in compliance with the following standards:

**UL 723 Surface Burning Characteristic of Building Materials** <sup>1</sup> (ASTM E 84 test methods)

Flame Spread Index (FSI)

Interior Finish – FSI less than 200

Hidden or Concealed Insulation – FSI less than 25

Smoke Developed Index (SDI) less than 450

**CAN/ULC S102 Surface Burning Characteristic of Building Materials and Assemblies** <sup>1</sup>

Flame Spread Index (FSI) less than 150

Smoke Developed Index (SDI) less than 300

**International Building Code (IBC) Section 1607.13**, Interior Walls and Partitions, tested in accordance with ASTM E72-13a Strength Test of Panels for Building Construction, Section 12, Transverse Load.

**International Building Code (IBC) Section 2403.4 Interior Glazed Areas** <sup>2</sup>, all safety glass is specified to meet industry and regulatory standards, including unsupported glazing edge test, ANSI Z97.1

<sup>1</sup> This test specification is outside our Scope of Accreditation. This testing was performed by an accredited independent lab.

<sup>2</sup> This specification is not included in the Steelcase Laboratory's scope of accreditation.

Steelcase uses its own ISO 9001 registered and ISO 17025 accredited laboratories, and accredited independent laboratories, to verify compliance to the Standards and requirements listed. A list of accredited independent laboratories is available upon request.

Sincerely,

Jeff Musculus – Director, Global Testing  
PH 616-698-4685, Email [jmusculu@steelcase.com](mailto:jmusculu@steelcase.com)

**Note:**

This document may be reproduced in full only.

Steelcase products are designed and tested for code and standard compliance when installed and used as an integrated product solution in accordance with Steelcase application guidelines and assembly directions. The use of unauthorized non-Steelcase components, parts, or materials with integrated Steelcase product solutions **VOIDS** all Steelcase claims of product compliance to BIFMA, UL, CSA, LEED, and / or any office furniture safety or performance standards, including all building, fire, and electrical codes. This exclusion includes but is not limited to the use of non-Steelcase panel supported work surfaces, leg supports, panels, brackets, shelves, overhead bins, and other integral components. The use of non-Steelcase components in an integrated product solution not designed, tested, or supported, by Steelcase is an unauthorized modification of the original product which voids all Steelcase warranties, expressed or implied.