



Product Compliance Laboratory Confirmation of Product Compliance



4-Jun-2025

Steelcase Lite Scale products have been tested and comply with the following sections of the International Building Code (IBC) 2024: ¹

2403.1 and 2406.3 Identification

Each pane of glass is permanently etched in accordance with ANSI Z97.1 and CPSC 16 CRG Part 1201 Safety Glazing.

2403.3 Glass Framing

Edge deflection at framing does not exceed L/175 or 3/4 inch when tested in accordance with ASTM E72 Strength Test of Panels for Building Construction, Section 12, Transverse Load. ²

2403.4 Interior Glazed Areas

Unsupported adjacent edges do not deflect more than panel thickness when subjected to 50 lb/ft linear load.

2406 Safety Glazing

Each pane of glass is Tempered or Laminated Safety Glass in accordance with ANSI Z97.1 and CPSC 16 CFR Part 1201.

¹ This specification is not included in Steelcase Laboratory's scope of accreditation, unless otherwise noted.

² This specification is included in Steelcase Laboratory's scope of accreditation.

Steelcase uses its own ISO 9001 registered and ISO 17025 accredited laboratories, and accredited independent laboratories, to verify compliance to the Standards and requirements listed. A list of accredited independent laboratories is available upon request.

Sincerely,

Jeff Musculus – Director, Global Testing
PH 616-780-5344, Email jmusculu@steelcase.com

Note:

This document may be reproduced in full only.

Steelcase products are designed and tested for code and standard compliance when installed and used as an integrated product solution in accordance with Steelcase application guidelines and assembly directions. The use of unauthorized non-Steelcase components, parts, or materials with integrated Steelcase product solutions VOIDS all Steelcase claims of product compliance to BIFMA, UL, CSA, LEED, and / or any office furniture safety or performance standards, including all building, fire, and electrical codes. This exclusion includes but is not limited to the use of non-Steelcase panel supported work surfaces, leg supports, panels, brackets, shelves, overhead bins, and other integral components. The use of non-Steelcase components in an integrated product solution not designed, tested, or supported, by Steelcase is an unauthorized modification of the original product which voids all Steelcase warranties, expressed or implied.